

SPRAWOZDANIE Z BADAŃ NR 397441/19/SCZ

Zleceniodawca "WODOCIĄGI ZACHODNIOPOMORSKIE" SPÓŁKA Z O.O. I BRYGADY LEGIONÓW 8-10 72-100 GOLENIÓW		Próbka (wg deklaracji Zleceniodawcy) WODA UZDATNIONA Data poboru: 26.08.2019 Godzina poboru: 9:10-9:20 Punkt poboru, miejsce poboru: Wodociąg Miłowo gmina Stepnica woda uzdatniona z sieci wodociągowej Gąsierzyno klub Próbki pobrane przez Zleceniodawcę Stan próbki bez zastrzeżeń Próbki dostarczone przez Zleceniodawcę	
Data przyjęcia próbki:	2019-08-26		
Data zakończenia badań:	2019-08-29		
Data utworzenia sprawozdania:	2019-08-29		

Rodzaj badania	Metoda	Jednostka	Wynik	Kryteria	Parametr zgodny/niezgodny
* Liczba bakterii z grupy coli ¹⁾²⁾	PN-EN ISO 9308-1:2014-12+A1:2017-04	jtk/100 ml	0	0	zgodny
* Liczba Escherichia coli ¹⁾²⁾	PN-EN ISO 9308-1:2014-12+A1:2017-04	jtk/100 ml	0	0	zgodny
* Ogólna liczba mikroorganizmów w 22°C po 72h ¹⁾²⁾	PN-EN ISO 6222:2004	jtk/ml	70 [48; 100]	-	-

¹⁾ Rozporządzenie Ministra Zdrowia z dnia 7 grudnia 2017 r. w sprawie jakości wody przeznaczonej do spożycia przez ludzi (Dz. U. 2017, poz. 2294).

²⁾ Badania wykonano metodami zatwierdzonymi przez Państwowego Granicznego Inspektora Sanitarnego w Szczecinie (decyzja nr ONS.HK.5002.1.2019 z dnia 08.03.2019r.)

KONIEC SPRAWOZDANIA

Authorized by: Anna Polanin, Kierownik Pracowni Mikrobiologii Szczecin

Approved by: Hanna Wachowska, Dyrektor Naczelny Laboratorium (Approved with electronic signature)

Laboratory: Szczecin 70-605, ul. Ks. Stanisława Kujota 8

The results relate to the analysed samples only. Unless otherwise specified given measurement uncertainty was estimated for the coverage factor k=2 at 95% confidence level. Sampling uncertainty has not been taken into consideration. This Report cannot be reproduced partially without a prior written consent of J.S. Hamilton Poland Sp. z o.o. Responsibility of J.S. Hamilton Poland Sp. z o.o. is restricted exclusively to the results and statements presented in original copy of the Report. The service confirmed by this Report is subject to the General Terms and Conditions of Services of J.S. Hamilton Poland Sp. z o.o. published on www.hamilton.com.pl

* Test method accredited; # Test performed by subcontractor

Page 1 / 1

Formularz PO-14/08d wyd. z dn. 27.03.2019

J.S. HAMILTON POLAND Sp. z o.o.
TESTING LABORATORY

ul. Chwaszczyńska 180, 81-571 Gdynia, Poland, tel. +48 58 766 99 00

